



State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES

6 Hazen Drive, P.O. Box 95, Concord, NH 03302-0095
(603) 271-3503 FAX (603) 271-5171



October 9, 2003

LETTER OF DEFICIENCY #WSEB 03-272
Certified Mail 7000 0600 0023 9933 7906

Dorothea Santurri
Pine River Mobile Home Park
PO Box 217
Ossipee, NH 03864

Subject Ossipee – Public Water System: Pine River Mobile Home Park (EPA #1843020)

Dear Ms. Santurri

The records of the Department of Environmental Services (DES) show that the Pine River Mobile Home Park water system is classified as a public water system (PWS), as defined by RSA 485:1-a. A PWS is defined as any water system serving 15 or more services, or 25 or more people for 60 or more days per year. As such, the water system owner is required to submit samples to the State laboratory or a State-certified laboratory for coliform bacteria analysis in compliance with NH Administrative Rule Env-Ws 325.

DES records show that Standard Maximum Contaminant Level (MCL) violations for total coliform bacteria, as defined in NH Admin. Rule Env-Ws 315.01 have occurred and that letters of violation were issued for the following months:

November 2002 and September 2003

DES believes the MCL violations can be corrected and future violations prevented by taking the following actions:

By October 23, 2003, retain the services of a qualified water system consultant to address the system's water quality problems relative to the recent bacteriological occurrences; and

By November 6, 2003, submit to DES for review a copy of the consultant's report which shall include recommendations to correct the bacteria contamination; and

By November 20, 2003, submit to DES for review and approval an implementation schedule which identifies specific dates by which steps to correct the bacteria contamination will be accomplished.

Pursuant to Env-Ws 351, owners of public water systems are required to issue public notification when a system has exceeded the MCL limit for coliform bacteria. DES records show that the water system has failed to perform public notification for the November 2002 MCL violation. To date, the water system has not submitted proof of public notice for the September 2003 MCL violation.

In view of the public notice violation, DES believes the deficiency can be corrected, and future violations prevented, by taking the following actions:

4. **By October 23, 2003**, carry out the public notice requirements for the November 2002 and September 2003 MCL violations listed above; and
- 5 **By November 6, 2003**, provide proof of public notice to DES

In the event compliance is not achieved within this period, DES may take further enforcement action, including issuing an order requiring the deficiencies be corrected, initiating an administrative fine proceeding and/or referring the matter to the NH Department of Justice for imposition of appropriate penalties.

The copy of the consultant's written report **and the implementation schedule** as requested above should be addressed as follows:

Anne S. Bailey
Department of Environmental Services
Water Supply Engineering Bureau
6 Hazen Drive, P.O. Box 95
Concord, NH 03302-0095

Please contact Anne Bailey by phone at (603) 271-0672, or by e-mail at abailey@des.state.nh.us if you have any questions regarding this letter.

Sincerely,

 **COPY**

Anthony P. Giunta, P.G., Administrator
Water Supply Engineering Bureau

\\web-enfmon\enforce\lods\bact\1843020 mcl lod 272.doc

Gretchen Rule, DES Legal Unit
Town of Ossipee Health Officer
Stanley Oliver, Yankee Pump & Filter Co., Primary Operator
EPA Region I